

Weekly testing !!!

Date: November 21st 2000

Page 3 of 19

Please test for the following highlighted . . . . .

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

Discharge Limitations

Monitoring Requirements

<u>Regulated Parameter</u>	<u>Maximum for Any one Day mg/L</u>	<u>Monitoring Frequency</u>	<u>Sample Type</u>
Cadmium[5]	.02	Semi-Annual	Composite[2]
Total Chromium[5]	2.0	Semi-Annual	Composite[2]
Copper[5]	0.60	Semi-Annual	Composite[2]
Cyanide	0.50	Semi-Annual	Grab
Lead[5]	0.10	Semi-Annual	Composite[2]
Nickel[5]	0.80	Semi-Annual	Composite[2]
Silver[5]	0.24	Semi-Annual	Composite[2]
Zinc[5]	1.25	1 X Week	Composite[2]
Oil and Grease[6]	100	Semi-Annual	Grab
TPH[6]	(Monitor and report)	Semi-Annual	Grab
pH	6-10	Daily	Grab
CBOD [4]	(Monitor and report)	1 X Month	Composite[2]
Ammonia [4]	(Monitor and report)	1 X Month	Composite[2]
COD [4]	(Monitor and report)	1 X Month	Composite[2]
TSS [4]	(Monitor and report)	1 X Month	Composite[2]
Flow	N/A	Daily [3]	
TTO	2.13	Semi-Annual	Grab
Phenol	0.50	Semi-Annual	Grab
Molybdenum[5]	(Monitor and report)	1 X Month	Composite[2]

DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 1 DAY-OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

## PART I

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

#### Discharge Limitations

#### Monitoring Requirements

	Regulated Parameter	Maximum for Any one Day mg/L	RESULT	DATE TAKEN	Monitoring Frequency	Sample Type
<i>Cd</i>	Cadmium[5]	.02			Semi-Annual	Composite[2]
<i>Cr</i>	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
<i>Cu</i>	Copper[5]	0.60			Semi-Annual	Composite[2]
<i>Ca</i>	Cyanide	0.50			Semi-Annual	Grab
<i>Pb</i>	Lead[5]	0.10			Semi-Annual	Composite[2]
<i>Ni</i>	Nickel[5]	0.80			Semi-Annual	Composite[2]
	Silver[5]	0.24			Semi-Annual	Composite[2]
<i>Zn</i>	Zinc[5]	1.25	<i>&lt;0.020</i>	<i>11-9-00</i>	1 X Week	Composite[2]
<i>FOG</i>	Oil and Grease[6]	100			Semi-Annual	Grab
<i>OIL + GREASE HYDROCARBONS</i>	TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pH	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)			1 X Month	Composite[2]
<i>Nh3</i>	Ammonia [4]	(Monitor and report)			1 X Month	Composite[2]
	COD [4]	(Monitor and report)			1 X Month	Composite[2]
	TSS [4]	(Monitor and report)			1 X Month	Composite[2]
	Flow	N/A			Daily [3]	
<i>*</i>	TTO	2.3			Semi-Annual	Grab
	Phenol	0.50			Semi-Annual	Grab
<i>Mo</i>	Molybdenum[5]	(Monitor and report)			1 X Month	Composite[2]

AND TIO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR  
REGORICAL STATEMENT MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)